

Classification Report



BASEC Client **Caleb Cable Industrial Limited**

Report No. **KCPR1138 Classification Issue 3**

Number of pages in this Report: 6

Issue Date **5 June 2017**

Items Tested 1 sample of copper communication cable

Specification(s) BS EN 13501-6:2014

Authorised by: I McGuinness

Laboratory Manager

Issue Date: 5 June 2017

This Classification Report does not represent type approval or certification of the product. This Classification Report shall not be reproduced except in full, without written approval of the laboratory.

British Approvals Service for Cables
Presley House
Presley Way
Crownhill
Milton Keynes
MK8 0ES UK
T: 01908 267300
F: 01908 267255
E: mail@basec.org.uk
W: www.basec.org.uk



5950



Notified Body No. 2661

Introduction

This classification report defines the classification assigned to the product, a copper communication cable, in accordance with the procedures given in BS EN 13501-6:2014



**CLASSIFICATION OF REACTION TO FIRE
FOR ELECTRIC CABLES IN ACCORDANCE WITH
BS EN 13501-6:2014**

Sponsor:	Caleb Cable Industrial Limited
Prepared for:	Caleb Cable Industrial Limited
Place of Manufacture:	107 Luyuan Road, Ke Yuan Cheng, Tangxia, Dongguan, China
Prepared by:	British Approvals Service for Cables, Presley House, Presley Way, Crownhill Milton Keynes, MK8 0ES, United Kingdom
Notified Body No.	2661
Classification Report No.	KCPR1138 Classification – Issue 3
Issue number:	3
Date of issue:	5 June 2017

This classification report consists of 6 pages and may only be used or reproduced in its entirety.

BASEC Report No: KCPR1138 Classification Issue 3

Details of classified product

General

This classification report defines the classification for the copper communication cable in accordance with the procedures given in BS EN 13501-6:2014.

Product description

The copper communication cable is as described in Sample details below.

Traceability

The test samples submitted by the manufacturer and received on 14 November 2016.

Sample details

Parameter	Details
Test sponsor	Caleb Cable Industrial Limited
Manufacturer of sample	Caleb Cable Industrial Limited
Place of manufacture	107 Luyuan Road, Ke Yuan Cheng, Tangxia, Dongguan, China
Cable submitted for test	
S-FTP Cat 6a/Cat7/Cat7a LSZH Dual 23 AWG	2x (4 pairs of PE insulated copper conductors, individual pair shield, overall wire braid screen, LSZH jacket): 7.4mm x 15.2mm Product code CCSFTPCAT6a/Cat7/Cat7a8P

BASEC Report No: KCPR1138 Classification Issue 3

Reports & results in support of this classification

Reports

Name of Laboratory	Name of test sponsor	Test reports Nos.	Test method/field of application rules
BASEC	Caleb Cable Industrial Limited	KCPR1138	BS EN 50399:2011 BS EN 60332-1-2:2004 + A1:2015
UL LLC		LCPR1313	BS-EN 60754-2:2014

Results

Test method & test number	Parameter	No. tests run	Results	
			Continuous parameter	Compliance with parameters
BS EN 50399:2011	FS	1	2.10m	>2.0m / D _{ca} Compliant
	THR _{1200s}		17.9MJ	≤ 30MJ/ C _{ca} Compliant
	Peak HRR		88.2kW	≤ 400W / D _{ca} Compliant
	FIGRA		331.5W/s	≤ 1300W/s / D _{ca} Compliant
BS EN 60332-1-2:2004 + A1:2015	TSP _{1200s}	1	35.4m ²	≤ 50m ² / s1 Compliant
	Peak SPR		0.11m ² /s	≤ 0.25m ² /s / s1 Compliant
	Flaming droplets/particles	1	>10s	flaming drips >10s / d2 compliant
BS EN 60754-2:2014	pH/conductivity	3	pH = 5.93* conductivity = 1.98μS/mm*	pH = >4.3 and < 2.5μS/mm = a1 compliant

* Weighted average of all components tested

BASEC Report No: KCPR1138 Classification Issue 3

Classification and field of application

Reference of classification

This classification has been carried out in accordance with BS EN 13501-6:2014

Classification

The copper communication cable in relation to reaction to fire behaviour is classified:

D_{ca}

The additional classification in relation to smoke production is:

s1

The additional classification in relation to flaming droplets / particles is:

d2

The additional classification in relation to acidity is:

a1

The format of the reaction to fire classification for electric cables is:

Fire Behaviour		Smoke Production			Flaming Droplets			Acidity	
D _{ca}	-	s	1	,	d	2	,	a	1

Reaction to Fire Classification: D_{ca}-s1,d2,a1

The classification assigned to the products in this report is appropriate to a declaration of conformity by the manufacturer within the context of system 3 attestation of conformity and CE marking under the Construction Products Regulation.

The test laboratory has, therefore, played no part in sampling the product for the test, although it holds appropriate references, supplied by the manufacturer, to provide for traceability of samples tested.

BASEC Report No: KCPR1138 Classification Issue 3

Field of application

This classification is valid for the copper communication cable described in 'Sample details' and listed below

Cable Identification	Product Code	Reaction to Fire Classification
S-FTP Cat6a/Cat7/Cat7a LSZH Dual 23 AWG	CCSFTPCAT6a/Cat7/Cat7a8P	D _{ca} -s1,d2,a1

This classification is valid for all end-use applications

Limitations

This classification will be valid whilst;

- The test methods remain unchanged,
- The product standard or technical approval remains unchanged,
- Constructional or material modifications do not exceed limits of the field of application.

The manufacturer has made a declaration, which is held on file, which the product placed in the marketplace, named in product description section of this report and produced at the manufacturing plant listed therein, is exactly the same as the product that was tested.

This classification document does not represent type approval or certification of the product.

-- END OF REPORT ---